



Amendment-II

Sub: Procurement – Tender for “Design, Supply, Installation, Testing and Commissioning of 200KWp Roof top Model Solar PV Power Plant” – Pre-bid conference – Amendment – issued..

Ref: 1) This office tender notification: RGUKT-B/Proc/SolarPower/T11/2016,dt. 26.12.2016

2) Pre-bid meeting held on 04.01.2017

RGUKT issued tender notification (vide reference 1st cited) for Design, Supply, Installation, Testing and Commissioning of 200KWp Roof top Model Solar PV Power Plant”. In connection with this tender, pre-bid conference was held on 04.01.2017. As per the recommendation of the Tender Committee the following amendments were issued:

S.No.	Page No. (Tender Ref.)	Clause	As per Tender document	Amendment
1	32	5.C.	Net worth of the company bidding or part of the consortium as the manufacturer of the PV Modules should be Min. of Rs.20 Cr. and above	Net worth of the company bidding or part of the consortium as the manufacturer of the PV Modules should be Min. of Rs.10 Cr. and above
2	12	6	No of cells per module shall be 60/72	No of cells per module 60/72 (or minimum wattage of 250)
3	9	4.0.	The contractor has to prepare total project (design) documents related to this work as per MNRE formats and obtain subsidy on behalf of RGUKT. RGUKT will sign on application forms to claim subsidy directly.	The prices quoted shall be net of all subsidies/incentives (factoring all subsidies/incentives applicable from State and Central Governments) and RGUKT shall not be liable for any claims of subsidy/incentive.
4	16/19	9	Wherever the Inverter/PCU mentioned it should be a String Inverter.	

All other terms remain the same.

Sd/-
Director